Certificate Number: NZ19/002

CERTIFICATE of APPROVAL

THIS IS TO CERTIFY that the article(s) described herein, subject to the conditions specified in the accompanying schedule, are approved pursuant to Regulation 85 of the Electricity (Safety) Regulations 2010.

ARTICLE: **Supply Flexible Cord - Heavy Duty Flexible Cords**

MODEL: **Nexans Versolex cable series,**
Heavy Duty, Multi-core, flexible copper conductors, 0.6/1kV,
X-90 insulated & PE (5V-90) sheathed cables (Articles) covered under this approval are below:-

2 Core + Earth - Flexible Cord
Type-EFGR04AA003CXKA - 2 X 1.5 mm^2 + Earth
Type-EFGR05AA003CXKA - 2 X 2.5 mm^2 + Earth
Type-EFGR06AA003CXKA - 2 X 4.0 mm^2 + Earth
3 Core + Earth - Flexible Cord
Type-GFGR04AA004CXDV - 3 X 1.5 mm^2 + Earth
Type-GFGR05AA004CXDV - 3 X 2.5 mm^2 + Earth
Type-GFGR06AA004CXDV - 3 X 4.0 mm^2 + Earth

APPROVAL HOLDER: **Nexans New Zealand Ltd.**

APPROVAL NUMBER: **NZ19/002**

APPROVAL STANDARD: **AS/NZS 3191: 2008 Electric flexible cords.**

ARTICLES TESTED BY: Nexans New Zealand Ltd. IANZ Endorsed Test Report LR2250 to AS/NZS 3191:2008

Dated at Wellington this 9 March 2020

Mark Wogan
Manager, Energy Safety – WorkSafe New Zealand
(Under delegated authority of the Chief Executive of WorkSafe)